

Weekly Eyewash Inspection Log

Location _____

Year: 2025

Instructions: Activate emergency eyewash to ensure proper operation.

- Sufficient water flows from eyewash.
- Streams of water meet in the middle/sufficiently can reach user eyes of the eyewash.
- Water is clear.

If there are any issues, tag unit out of service and call facilities at **203-432-6888** to request that the unit be repaired as soon as possible.

- Keep weekly eyewash inspection log sheet for 3 years.

Schedule: Researchers in laboratories registered with the State of Connecticut Department of Public Health are required to test and document the test weekly.

Week of	Date	Initials	Week of	Date	Initials	Week of	Date	Initials
12/29/2024			5/4/2025			9/7/2025		
1/5/2025			5/11/2025			9/14/2025		
1/12/2025			5/18/2025			9/21/2025		
1/19/2025			5/25/2025			9/28/2025		
1/26/2025			6/1/2025			10/5/2025		
2/2/2025			6/8/2025			10/12/2025		
2/9/2025			6/15/2025			10/19/2025		
2/16/2025			6/22/2025			10/26/2025		
2/23/2025			6/29/2025			11/2/2025		
3/2/2025			7/6/2025			11/9/2025		
3/9/2025			7/13/2025			11/16/2025		
3/16/2025			7/20/2025			11/23/2025		
3/23/2025			7/27/2025			11/30/2025		
3/30/2025			8/3/2025			12/7/2025		
4/6/2025			8/10/2025			12/14/2025		
4/13/2025			8/17/2025			12/21/2025		
4/20/2025			8/24/2025			12/28/2025		
4/27/2025			8/31/2025					